
ENVIRONMENTAL Fact Sheet



29 Hazen Drive, Concord, New Hampshire 03301 • (603) 271-3503 • www.des.nh.gov

WMD-REM-19

2005

Farm Tanks for the Underground Storage of Petroleum Products

Do you own an underground storage tank (UST) that has a capacity to store more than 110 gallons of MOTOR FUEL (gasoline, diesel, aviation, etc.)?

If the answer is YES, you should be aware that:

- You are required to register the tanks with the N.H. Department of Environmental Services.
- You must be in compliance with Underground Storage Tank Rules (Env-Wm 1401).
- You must clean up all spills and leaks in accordance with State rules (Env-Ws 412).
- If determined eligible, the Oil Discharge and Disposal Cleanup Fund (ODDCF) will reimburse you for the cost of cleanup associated with a leaking UST.
- All single-wall steel tanks must be removed or filled in place once they reach age 25 years old. Please notify N.H. Department of Environmental Services prior to closure.

For further information, please contact the DES Groundwater Protection Bureau at (603) 271-3644.

Disclaimer: Information contained in this Fact Sheet is current as of January 1, 2005. Statutory or regulatory changes that may occur after that date may cause part or all of the information to become invalid. If there are any questions concerning the current status of information, please contact DES at (603) 271-3644.